

## LEGAL NOTICES

**L873**  
**Public Notice:**  
The annual Meeting of the Early Development Network for Planning Region #14 is scheduled to review and discuss services offered to children with disabilities, birth to age five, and their families. The meeting is open to school district representatives, service providers, parents, non-public agencies serving children below age five, and other interested persons. The agenda may be obtained by contacting Pam Uhl at 308-254-4677. Tuesday, June 14, 2016 9:30 a.m. - 11:00 a.m. ESU #13, 1114 Toledo Street, Sidney, NE 69162  
[Published in The Sidney Sun-Telegraph on June 6, 2016]

**L874**  
**Notice of Meeting**  
Cheyenne County Historical Association Board  
Notice is hereby given that an open and public meeting of the Cheyenne County Historical Association Board will be held at 5:30 p.m. on Tuesday, June 14, 2016, at the Museum, 544 Jackson St., Sidney, Nebraska. An agenda for such meeting will be kept current and available to the public during normal business hours at the Cheyenne County Courthouse.  
/s/ Brenda Blanke  
Treasurer  
[Published in The Sidney Sun-Telegraph on June 6, 2016]

**L832**  
**NOTICE OF BOARD MEETING**  
The Board of Education of Potter-Dix Public Schools will hold a meeting on Monday June 13, 2016 at 8:00p.m.; in the Library at the Potter site. An updated agenda will be kept current in the office of the superintendent.  
/s/Mike Williams  
Superintendent  
[Published in The Sidney Sun-Telegraph on May 27 and June 6, 2016.]

## LEGAL NOTICE & AD DEADLINES

For Publication on: Notice Must Be Received By:

Monday.....3:00 P.M. Thursday  
Tuesday..... 3:00 P.M. Friday  
Wednesday..... 3:00 P.M. Monday  
Thursday..... 3:00 P.M. Tuesday  
Friday .....3:00 P.M. Wednesday

**SIDNEY SUN-TELEGRAPH**  
**308-254-2818**

**legals@suntelegraph.com • classifieds@suntelegraph.com**

### CITY OF SIDNEY ANNUAL WATER QUALITY REPORT FOR JANUARY 1 TO DECEMBER 31, 2015

This report is intended to provide you with important information about your drinking water and the efforts made by the City Of Sidney water system to provide safe drinking water.

**Para Clientes Que Hablan Español:** Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

For more information regarding this report, contact:  
**WILLIAM J (BILL) TAYLOR**  
308-254-5464

If you would like to observe the decision-making processes that affect drinking water quality, please attend the regularly scheduled meeting of the Village Board/City Council. If you would like to participate in the process, please contact the Village/City Clerk to arrange to be placed on the agenda of the meeting of the Village Board/City Council.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

**Source Water Assessment Availability:** The Nebraska Department of Environmental Quality (NDEQ) has completed the Source Water Assessment. Included in the assessment are a Wellhead Protection Area map, potential contaminant source inventory, vulnerability rating, and source water protection information. To view the Source Water Assessment or for more information please contact the person named above on this report or the NDEQ at (402) 471-6988 or go to [www.deq.state.ne.us](http://www.deq.state.ne.us).

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

**Sources of Drinking Water:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and groundwater wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

The source of water used by City Of Sidney is ground water.

Contaminants that may be present in source water include:  
\* Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.  
\* Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.  
\* Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.  
\* Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.  
\* Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

**Drinking Water Health Notes:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Infants, young children, and pregnant women are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested. Flushing your tap for 30 seconds to 2 minutes before using your tap water will clear the line of any lead that may have leached into the water while the line was idle. Additional information is available from the Safe Drinking Water Hotline (800-426-4791) or the DHHS/Division of Public Health/Office of Drinking Water (402-471-2541).

The City Of Sidney is required to test for the following contaminants: Coliform Bacteria, Antimony, Arsenic, Asbestos, Barium, Beryllium, Cadmium, Chromium, Copper, Cyanide, Fluoride, Lead, Mercury, Nickel, Nitrate, Nitrite, Selenium, Sodium, Thallium, Alachlor, Atrazine, Benzo(a) pyrene, Carbofuran, Chlordane, Dalapon, Di(2-ethylhexyl)adipate, Dibromochloropropane, Dioxin, Di(2-ethylhexyl)phthalate, Diquat, 2,4-D, Endothall, Endrin, Ethylene dibromide, Glyphosate, Heptachlor, Heptachlor epoxide, Hexachlorobenzene, Hexachlorocyclopentadiene, Lindane, Methoxychlor, Oxamyl (Vydate), Pentachlorophenol, Picloram, Polychlorinated biphenyls, Simazine, Toxaphene, Dioxin, Silvex, Benzene, Carbon Tetrachloride, o-Dichlorobenzene, Para-Dichlorobenzene, 1,2-Dichloroethane, 1,1-Dichloroethylene, Cis-1,2-Dichloroethylene, Trans-1,2-Dichloroethylene, Dichloromethane, 1,2-Dichloropropane, Ethylbenzene, Monochlorobenzene, 1,2,4-Trichlorobenzene, 1,1,1-Trichloroethane, 1,1,2-Trichloroethane, Trichloroethylene, Vinyl Chloride, Styrene, Tetrachloroethylene, Toluene, Xylenes (total), Gross Alpha (minus Uranium & Radium 226), Radium 226 plus Radium 228, Sulfate, Chloroform, Bromodichloromethane, Chlorodibromomethane, Bromoform, Chlorobenzene, m-Dichlorobenzene, 1,1-Dichloropropene, 1,1-Dichloroethane, 1,1,1,2-Tetrachloroethane, 1,2-Dichloropropane, Chloromethane, Bromomethane, 1,2,3-Trichloropropane, 1,1,1,2-Tetrachloroethane, Chloroethane, 2,2-Dichloropropane, o-Chlorotoluene, p-Chlorotoluene, Bromobenzene, 1,3-Dichloropropene, Aldrin, Butachlor, Carbaryl, Dicamba, Dieldrin, 3-Hydroxycarbofuran, Methomyl, Metolachlor, Metribuzin, Propachlor.

How to Read the Water Quality Data Table:  
The EPA and State Drinking Water Program establish the safe drinking water regulations that limit the amount of contaminants allowed in drinking water. The table shows the concentrations of detected substances in comparison to the regulatory limits. Substances not detected are not included in the table. The state requires monitoring of certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Therefore, some of this data may be older than one year. MCL (Maximum Contaminant Level) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. MCLG (Maximum Contaminant Level Goal) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. AL (Action Level) - The concentration of a contaminant which, if exceeded triggers treatment or other requirements which a water system must follow. MRDL (Maximum Residual Disinfectant Level) - The highest level of a disinfectant allowed in drinking water.

N/A - Not applicable.  
Units in the Table:  
ND - Not detectable.  
ppm (parts per million) = mg/L (milligrams per liter) - One ppm or one mg/L corresponds to 1 gallon of water in 1,000,000 gallons of water.  
ppb (parts per billion) - One ppb corresponds to 1 gallon of water in 1,000,000,000 gallons of water.  
pCi/L (Picocuries per liter) - Radioactivity concentration unit.  
ug/L (micrograms per liter) - Measurement of radioactivity.  
RAA (Running Annual Average) - An ongoing annual average calculation of data from the most recent four quarters.  
90th Percentile - Represents the highest value found out of 90% of the samples taken in a representative group. If the 90th percentile is greater than the action level, it will trigger a treatment or other requirements that a water system must follow.  
TT (Treatment Technique) - A required process intended to reduce the level of a contaminant in drinking water.

City of Sidney	TEST RESULTS Date Printed: 6/3/2016	NE3103303			
Microbiological	Highest No. of Positive Samples	MCL			
No Detected Results were Found in the Calendar Year of 2015	MCLG	Likely Source of Contamination			
Lead and Copper	Monitoring Period	90th Percentile	Range	Sites Over AL	Likely Source of Contamination
COPPER, FREE	2012 - 2014	0.481	0.00551 - 0.695	0	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing
LEAD	2012 - 2014	4.84	1.02 - 21.1	1	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing
Regulated Contaminants	Collection Date	Highest Value	Range	MCLG	Likely Source of Contamination
ARSENIC	06/16/2015	7.03	6.41 - 7.03	0	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
BARIUM	10/19/2015	0.128	0.128	2	Discharge from drilling wastes; Discharge from metal refineries; Erosion of natural deposits
FLUORIDE	10/19/2015	0.698	0.698	4	Erosion of natural deposits; water additive which promotes strong teeth; Fertilizer discharge
NITRATE-NITRITE	08/11/2015	9.75	1.5 - 9.75	10	Runoff from fertilizer use; Leaching from septic tanks; sewage; Erosion of natural deposits
Disinfection Byproducts	Monitoring Period	Highest RAA	Range	MCLG	Likely Source of Contamination
TOTAL HALOACETIC ACIDS (THAA)	1/1/2015 - 12/31/2015	2.435	2.36 - 2.51	0	By-product of drinking water disinfection
TTHM	1/1/2015 - 12/31/2015	7.2	6.4 - 8	0	By-product of drinking water disinfection
Radionuclide Contaminants	Collection Date	Highest Value	Range	MCLG	Likely Source of Contamination
GROSS ALPHA, INCL. RADON & U	08/20/2013	11.5	4.8 - 11.5	0	Erosion of natural deposits
Unregulated Water Quality Data	Collection Date	Highest Value	Range	Unit	Secondary MCL
NICKEL	10/19/2015	0.00214	0.00119 - 0.00214	mg/L	0.1
SULFATE	04/21/2015	56.4	44.6 - 56.4	mg/L	250

During the 2015 calendar year, we had the below noted violation(s) of drinking water regulations.

Type	Category	Analyte	Compliance Period
No Violations Occurred in the Calendar Year of 2015			

**The City Of Sidney has taken the following actions to return to compliance with the Nebraska Safe Drinking Water Act:**  
This report will not be mailed. A copy can be requested at City of Sidney offices, 1115 13th Ave.

Additional Required Health Effects Language:  
While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.  
Infants and children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4761).

#875 June 6, 2016

# CLASSIFIEDS

**HELP WANTED**  
**PART TIME AND FULL TIME EMPLOYEES** at \$9.00 an hour. Apply in person at either Git N Split location EOE.

Progressive veterinary practice in Sidney seeks an outstanding full-time

vet technician. Duties include safe handling and restraint of small and large animals, venipuncture, placement of IV catheters, anesthetic monitoring, dental cleanings, assisting in radiology, and obtaining accurate medical records.

Ideal candidates will possess strong communication, organizational, interpersonal, and technical skills; experience a plus. We offer competitive compensation, a friendly and fast paced environment, and career growth opportuni-

ties. Email cover letter and resume to [jnelson@omnexusgroup.com](mailto:jnelson@omnexusgroup.com).

**MISC.**  
**WE BUY ALUMINUM CANS.** WE PAY CASH. 955 BALL ST, SIDNEY. 254-7115.

**APTS FOR RENT**  
Studio, 1 & 2 Bedroom Apartments for lease. \$400 & up, all utilities pd. 1 month deposit & background check. 308-254-0913

**HOUSES FOR RENT**  
House for Rent. For more info, call 249-1053.  
3 bedroom, nice location in Sidney, garage, fenced back yard  
308-879-4523

2 bedroom, nice location in Sidney, oak floors. \$600 per month. 308-879-4523  
2 bedroom, nice location in Sidney. Large lot. \$500 per month. 308-879-4523

**SERVICES**  
**THE CARPET SURGEON**  
Need your carpet restretched or repaired? Call Larry Dickinson 308-874-2766.  
50 years experience.